

# Full-scale Performance of the Pressurized Screw Press dehydrator (Type III)




# Table of Contents

1. Overview of screw press dehydrator Type III (SP3)
2. Number of Adoption
3. Objectives of Ex-post Evaluation
4. Approaches
5. Results
6. Example of Failures, Request for Improvement
7. Sludge Property Analysis Results
8. Conclusions



# Overview of SP3 (1)

- ⊙ Constant flow treatment
- ⊙ High concentration of coagulated sludge





# Overview of SP 3 (2) Prescribed values

- ◆ Treatment capacity, chemical doses, SS recovery rate  
⇒ Apply design values of SP2 set at the JS Innovation Program


	Reduction point of cake's water content rate (Against water content rate of cake dewatered by SP2)	
	Polymer coagulant: one liquid conditioning	Polymer/inorganic coagulant : two-liquid conditioning
Mixed raw sludge	-6	-10
Anaerobic digested sludge	-5	-8
Excess sludge	-4	-5



# The Number of Adoption

Over 40 WWTPs have adopted SP3.

SP3 occupies 57% of practical application examples of JS Innovation Program.





# Objectives of Ex-post Evaluation

- Many records of adoption
  - 43 SP3s introduced to JS projects
  - 48 SP3s adopted by municipal WWTPs directly
- To encourage further adoption and follow up after the introduction:
  - **Confirm actual performance**
  - Investigate problems some machines have
  - Ask O&M administrator **requests for improvement**
  - **Make a close analysis of sludge properties** and investigate their impact on the performance of SP3



# Approaches

statistics  
 JS' achievements  
 Hearing survey to  
 manufacturer:  
 Ishigaki Company,  
 Ltd.

- Figure out sludge properties
- Confirm WWTPs to be surveyed

Survey period	Nov & Dec 2019
Focused group	51 SP3 of 48 municipalities
Mailed questionnaire	34 of 28
Valid answers	23 of 18
Test operation data	26 of 23
Annual/monthly report data	19 of 15

Questionnaire  
 survey

- Verify the dewaterability at test /everyday operations
- Problems, Requests for the improvement

Field survey  
 Sludge property  
 analysis

- Conduct a field survey at 2 WWTPs
- Close analysis of sludge properties of 6 willing municipal WWTPs




# Survey Results: Test Operations

Treatment capacity: the relative difference between data and prescribed value


While some SP3s achieved neither of them, treatment capacity and water content rate were verified to have reciprocity mostly.

80% of SP3s achieved proscribed treatment capacity



Water content rate: the relative difference between data and prescribed value

60% of SP3s achieved proscribed water content rate







# Survey Results: Dewaterability

- Classify dewaterability by water content rate and treatment capacity
- Categorize dewaterability into A to E by the relative difference between operation data and prescribed values

※Relative difference between data and prescribed value (%)

$$= \left\{ \frac{(Data - Prescribed\ value)}{Prescribed\ value} \right\} \times 100$$

**Ex1: Calculation formula of water content rate**  
 When prescribed value is 76% and data is 79%,  
 relative difference of water content rate(%) =  $\left\{ \frac{(79 - 76)}{76} \right\} = 3.94$   
 ⇒ Therefore, water content rate is 3.94% higher than (inferior to) the prescribed value

**Ex2: Calculation formula of treatment capacity**  
 When prescribed value is 30kgDS and data is 32kgDS,  
 relative difference of treatment capacity(%) =  $\left\{ \frac{(32 - 30)}{30} \right\} \times 100 = 6.66$   
 ⇒ Therefore, treatment capacity is 6.66% higher(better) than the prescribed value

		← Treatment capacity satisfies prescribed value		→ Below prescribed value	
Water content rate satisfies prescribed value	Treatment capacity	10% or more than the prescribed value	Less than ±10% difference with the prescribed value	10% or less than the prescribed value	
Water content rate	1.0% or less than the prescribed value	<b>Category A:</b> much better performance than the prescribed value 4, 6-2, 8, 16, 36-2, 42, 43	<b>Category B:</b> better performance than the prescribed value 7, 10-1, 14(1), 36-1	<b>Category C:</b> Equivalent performance to the prescribed value 14(2), 15	
	Less than ±1.0% difference with the prescribed value	<b>Category B:</b> better performance than the prescribed value 2, 27	<b>Category C:</b> Equivalent performance to the prescribed value 3, 18	<b>Category D:</b> less performance than the prescribed value	
Below prescribed value	1.0% or more than the prescribed value	<b>Category C:</b> Equivalent performance to the prescribed value 1, 3, 5-1, 5-2, 13, 14-2, 15, 18, 19(1), 19(2), 40,	<b>Category D:</b> less performance than the prescribed value 10-2, 12	<b>Category E:</b> much less performance than the prescribed value 9, 17	




# Survey Results: Test Operations

## Categorizing by dewaterability using test operation data

Facility No.	Sludge property	water content rate achievement(%)	Grade	treatment capacity achievement(%)	Grade	category
16	Mixed raw sludge	92.9	Very good	115.8	Very good	A
8	Mixed raw sludge	96.9	Very good	176.9	Very good	A
36-2	Mixed raw sludge	97.5	Very good	131.5	Very good	A
4	Anaerobic digestion	97.6	Very good	117.6	Very good	A
42	Excess sludge	98.0	Very good	119.3	Very good	A
6-2	Mixed raw sludge	98.3	Very good	135.5	Very good	A
43	Anaerobic digestion	98.9	Very good	172.7	Very good	A
7	Mixed raw sludge	91.2	Very good	92.3	Average	B
10-1	Mixed raw sludge	93.7	Very good	106.9	Average	B
14(1)	Mixed raw sludge	94.9	Very good	97.9	Average	B
36-1	Mixed raw sludge	98.6	Very good	106.1	Average	B
2	Mixed raw sludge	99.1	Average	163.8	Very good	B
27	OD sludge	100.0	Average	121.4	Very good	B
14(2)	Mixed raw sludge	92.5	Very good	87.9	Poor	C
15	Mixed raw sludge	96.0	Very good	83.8	Poor	C
18	OD sludge	99.9	Average	105.2	Average	C
3	OD sludge	100.2	Average	99.4	Average	C
19(1)	OD sludge	101.2	Poor	155.7	Very good	C
19(2)	OD sludge	101.7	Poor	168.1	Very good	C
40	Anaerobic digestion	102.1	Poor	178.7	Very good	C
1	Mixed raw sludge	102.5	Poor	171.7	Very good	C
5-2	Mixed raw sludge	104.1	Poor	130.6	Very good	C
5-1	Mixed raw sludge	104.5	Poor	129.7	Very good	C
13	Mixed raw sludge	107.5	Poor	225.3	Very good	C
12	Mixed raw sludge	102.7	Poor	103.4	Average	D
10-2	Mixed raw sludge	103.1	Poor	106.6	Average	D
17	Anaerobic digestion	101.5	Poor	84.7	Poor	E
9	Mixed raw sludge	106.1	Poor	66.5	Poor	E

While some cases of **mixed raw sludge** and **anaerobic digested sludge** did not achieve their goals, most SP3 satisfied prescribed values **in the test operation**.





# Survey Results: Everyday Operations

## Categorizing by dewaterability using everyday operation data

Facility No.	Sludge property	water content rate achievement(%)	Grade	treatment capacity achievement(%)	Grade	category
6-1	Mixed raw sludge	97.60	Very good	121.91	Very good	A
11	Mixed raw sludge	98.67	Very good	162.41	Very good	A
35-1	Anaerobic digestion	98.91	Very good	114.48	Very good	A
6-2	Mixed raw sludge	99.07	Average	121.91	Very good	B
41	OD sludge	100.39	Average	133.02	Very good	B
35-2	Anaerobic digestion	98.96	Very good	102.60	Average	B
1	Mixed raw sludge	96.40	Very good	79.66	Poor	C
12	Mixed raw sludge	99.01	Average	100.00	Average	C
10-2	Mixed raw sludge	99.27	Average	108.10	Average	C
10-1	Mixed raw sludge	99.41	Average	103.68	Average	C
13	Mixed raw sludge	102.00	Poor	141.85	Very good	C
43	Anaerobic digestion	102.00	Poor	143.33	Very good	C
40	Anaerobic digestion	102.15	Poor	160.78	Very good	C
30	Anaerobic digestion	100.38	Average	70.28	Poor	D
27	OD sludge	100.79	Average	86.67	Poor	D
5-1	Mixed raw sludge	101.76	Poor	93.64	Average	D
5-2	Mixed raw sludge	101.76	Poor	93.64	Average	D
3	OD sludge	101.20	Poor	71.52	Poor	E
39	OD sludge	102.35	Poor	71.43	Poor	E
9	Mixed raw sludge	106.97	Poor	55.68	Poor	E


At everyday operations,

- 70% of mixed raw sludge
- 80% of anaerobic digested sludge

• Only 20% of OD sludge

Satisfied prescribed values.

So, OD sludge requires the performance improvement.



No reduction of sludge water content rates was verified when sludge treatment volumes were declined at everyday operations.



# Failures, Request for Improvement


## Solutions for improvement requests

Category	Reported answers	No. of answers
Problem	Leakage and corrosion of inspection access, inspection window, and outer cylinder cover	6
	The clog of washing nozzle	5
	Problems of measuring instruments	5
	The clog of sludge/chemical pipes	4
	Leakage from thickening parts	3
Trouble	Caused by low water content rate	4
Requests	The improvement of outer cylinder cover, inspection access, and inspection window	8
	Simplification of dewatering conditions adjustment	6
	The improvement of washing water pipe strainer	3
	Simplification of washing nozzle cleaning	3

Outer cylinder cover  
 → Redesign shape and structure  
 → Workability improvement of inspection access



Washing nozzle, strainer  
 → Review specifications  
 → Add checking items for supply water quality



Troubles from low water content rates  
 → Add checking items for facilities planning



# Sludge Property Analysis Results

WWTP		1	2	3	4	5	6
Sludge kind		Mixed raw sludge	Anaerobic digestion	Anaerobic digestion	Anaerobic digestion	OD process	OD process
Category by dewaterability		C	A,B	C	D	B	E
Thickening process		Gravity	Gravity Mechanical	Mechanical	Gravity Mechanical	Gravity	Mechanical
Analysis items / Supplied sludge							
TS	%	1.8	1.3	2.5	1.9	1.8	3.6
VTS	%	86.0	73.3	73.8	76.4	90.5	85.9
Fibrous material (mesh-100th)	%	1.3	3.8	8.7	5.8	3.6	6.5
Fibrous material (mesh-200th)	%	2.0	5.1	9.7	8.7	4.4	4.9
Crude protein	mg/L	7,400	4,800	8,100	6,500	7,700	13,000
Anion	meq/g-TS	0.27	0.68	0.65	0.69	0.23	0.31
M alkalinity	mg-Cac O <sub>2</sub> /L	320	3,400	6,800	4,100	180	780
Organic acid(total)	mg/L	1,100	<5	<5	<5	540	1,600
Carbohydrate	mg/L	<800	<800	<800	<800	<800	<800
Acid-soluble materials	mg/L	7,500	3,600	7,800	4,600	3,900	6,400
Alkali-soluble materials	mg/L	9,300	4,300	8,100	9,000	8,100	10,000
pH		6.0	7.6	7.6	7.5	5.7	6.0
SVI 3000	mg/L	4.0	17	23	18	16	16
Carbon (C)	%:dry sludge	42	37	39	41	43	44
Hydrogen (H)	%:dry sludge	6.3	5.8	6.4	6.4	6.5	7.1
Nitrogen (N)	%:dry sludge	8.0	6.5	6.3	6.7	9.2	7.2
Sulfur (S)	%:dry sludge	<1	<1	<1	<1	<1	<1
Oxygen (O)	%:dry sludge	29	30	19	29	29	18
Electric conductivity	ms/m	190	690	1,200	820	99	230
Colloidal equivalent	Meq/g-TS	-0.54	-1.3	-1.3	-1.3	-0.46	-0.63
Ammonia nitrogen (NH <sub>4</sub> -N)	mg/L	37	440	2,300	1,100	29	18
Nitrite nitrogen (NO <sub>2</sub> -N)	mg/L	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2
Nitrate nitrogen (NO <sub>3</sub> -N)	mg/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
Total phosphorus	mg/L	200	410	1,000	800	310	990
N-hexane extract	mg/L	110	100	<20	230	60	120
Biodegradability COD	mg/L	52	280	270	140	81	220
Refractory COD	mg/L	31	430	580	400	25	130
Solubility COD	mg/L	83	720	850	550	100	350
Calcium	mg/L	160	190	600	260	100	400
Magnesium	mg/L	20	73	250	110	48	110
Analysis item / Dewatered sludge							
Water content rate	%	82.2	80.8	83	78.8	81.5	83.8

The analysis showed that many sludge properties other than TS/VTS/fibrous materials influence dewaterability.

For example,

- Crude protein,
  - M alkalinity,
  - Organic acid,
  - Electric conductivity
- have an impact on only the OD process sludge.

On the other hand,

- N hexane
- affects both anaerobic digestion sludge and OD process sludge.

The study will continue using more samples.



# Conclusions

- ◆ From test/everyday operation data

- While having a necessary performance as a dehydrator, SP3 shows no good achievement for OD sludge at the everyday operations.

- Performance improvement for OD sludge

- ◆ From failures and request for improvement

- Maintainability of large-sized outer cylinder covers, clogged washing nozzles and strainers, hard adjustment of dewatering parameters

- Improve the shape of an outer cylinder cover, verify the quality of supplied wastewater

- ◆ From sludge property analysis data

- Factors having impacts on dewaterability: Crude protein for anaerobic and OD sludge, Organic acid for OD sludge

- Continuous research is scheduled this year for a centrifugal dehydrator with inside two-agents conditioning and SP2 dehydrator



**We sincerely appreciate  
municipalities for their  
cooperation.**

**Thank you for your attention.**